

INSPECTIONLIST

FOR ANNUAL INSPECTION – FALLNET® SR

Object:

Client/owner requesting the inspection:

Name:

Company:

Address:

Contractor:

Name:

Company:

Address:

Day of inspection:

Serial number:

General Inspection

Yes No

Is the amount and serial number of the anchor device according to the Inspection Chart?
If no Inspection Chart is available a new one is to be issued.

Inspection per anchor device Fallnet® SR

Yes No

Is a Zinco planning available?

Is the installation according to above mentioned planning? e.g. min. 2.5 m distance to fall edge, max. 5° roof slope, length of rope etc.

Is the roof area according to the plans? Subsequent alterations and/or extensions may require an adjustment of the planning.

Does the location of the anchor devices seem reasonable? e.g. min. 2.5 m distance to fall edge, max. 5° roof slope, length of rope etc.

Is the anchor device in a proper condition? e.g. no strain from fall arrest or similar, no damage, deformation, corrosion, etc.

Does the anchor device stay in place when pulled slightly?

Is the identification label clearly readable?

Is there enough ballast? Please refer to identification label for manufacture date:

Installation up to 12/2015: Up to 2° roof slope min. 90kg/m²,
from 2° to 5° roof slope min. 110 kg/m²

Installation from 01/2016: Up to 2° roof slope min. 110 kg/m²,
from 2° to 5° roof slope min. 130 kg/m²

Bulk material e.g. growing media (dry weight after settling), pebbles, etc.

Attachments:

- A. Photos of the anchor points and identification labels
- B. Measurement results of the bulk material for calculation of ballast.

Note:

Points marked with „No“ are to be documented in detail and made available to the client immediately. If there are concerns about the safe condition or the proper functioning of the anchor device it must be excluded from use!

The proper condition of the anchor device was observed

Date for next inspection:

Yes No

.....
Place / Date

.....
Signature

Zinco GmbH

Lise-Meitner-Strasse 2 | 72622 Nuertingen | Germany

Phone +49 7022 6003-0 | info@zinco-greenroof.com | www.zinco-greenroof.com

Subject to technical alterations and printing errors • First edition 04/2026

