

INSPECTIONLIST

FOR ANNUAL INSPECTION – FALLNET® SR RAIL

Object:

Client/owner requesting the inspection:

Name:

Company:

Address:

Prüfer (Auftragnehmer):

Name:

Firma:

Anschrift:

Day of inspection: Serial number(s):

General Inspection

Yes No

Is the amount and serial number(s) of the anchor device(s) (runner) according to the Inspection Chart? If no Inspection Chart is available a new one is to be issued.

Inspection per anchor device Fallnet® SR Rail

Yes No

Is a Zinco planning available?

Is the installation according to above mentioned planning?

Is the roof area according to the plans? Subsequent alterations and/or extensions may require an adjustment of the planning.

Is the anchor device in a proper condition? e.g. no strain from fall arrest or similar, no damage, deformation, corrosion, etc.

Is the anchor device (runner) permanently on the rail? e.g. at slight manual stress.

Exception: mobile, detachable runners with device to detach the runner.

Does the runner roll/glide smoothly on the rail?

Are the screw connections at joints and rail supports correct? e.g. not fastened/missing pieces

Is the gap at joints less than 5 mm?

Is the max. distance in between rail supports approx. 4,5 m?

Is the identification label clearly readable?

Is there enough ballast?

Up to 2° roof slope min. 110 kg/m², from 2° to 5° roof slope min. 130 kg/m² bulk material e.g. growing media (dry weight after settling), pebbles, etc.

Attachments: Photos and measurement results of the bulk material for calculation of ballast.

Note:

Points marked with „No“ are to be documented in detail and made available to the client immediately. If there are concerns about the safe condition or the proper functioning of the anchor device it must be excluded from use!

The proper condition of the anchor device was observed

Date for next inspection:

Yes No

.....
Place / Date

.....
Signature

Zinco GmbH

Lise-Meitner-Strasse 2 | 72622 Nuertingen | Germany

Phone +49 7022 6003-0 | info@zinco-greenroof.com | www.zinco-greenroof.com

Subject to technical alterations and printing errors • First edition 04/2026

